

Procurement Services Lucas Administrative Center, 617 1 Nunn Drive Highland Heights, KY 41099 859.572.6605 FAX 859.572.6995 ADDENDUM NO: 1

IFB/RFP No: NKU-34-19

Commodity: Kenton Dr. Parking Garage Restoration

Date: 4/3/2019

Due Date: 4/10/2019

BIDDER/RESPONDER SHALL CONFORM TO THE FOLLOWING CHANGES AS SAME SHALL BECOME BINDING UPON THE CONTRACT TO BE ISSUED IN RESPONSE TO THIS INVITATION FOR BID.

General:

Is this a prevailing wage project?

2. A question was raised about a substitute for the traffic coating for the project. The following answer is from the engineer / project manager:

The engineer specified 4 systems that are appropriate for the project and provide the supplemental warranty information required in the specifications. The systems are urethane based materials. The (substitute) system uses polyuria material. We do not think this is an appropriate substitution for the project.

Sheets 101,102 and 103:

1. Note 11 - please confirm general vertical sealant location. Interior CIP wall to column locations? Interior crack control chamfer joints?

Vertical sealant locations per note 11 exist at locations shown with hex note plus grid line E-11.5 all levels.

2. Note 16 - please confirm, are "security grills" the vertical, interior grating that exists at the bridge, vehicle barriers and stair rails?

Yes

- Note 14, 15, and 20 please confirm if all "security grills" are to prepared and painted? Yes
- 4. Note 22 & 23 some window walls exist at interior areas, do these units receive new sealant? Small partition walls at lower levels at A.2-2 and A.2-16 are not included.
- Note 24 will tuck pointing be required at exterior block surface that may require a man lift?
 Yes

Specification Section 071800 - Vehicular Traffic Membrane.

Change paragraph 2.1 to read as follows:

- 2.1 APPROVED MANUFACTURERS
 - A. Lymtal International
 - B. Neogard Corporation
 - C. Sika Corporation
 - D. BASF