



Procurement Services
Lucas Administrative Center, 617
1 Nunn Drive
Highland Heights, KY 41099
859.572.6605
FAX 859.572.6995

ADDENDUM NO: **1**

IFB/RFP No: ITB NKCC -06-2020

Project /Commodity: Norse Hall Exterior Repairs

Date: 05/08/2020

Due Date: May 15, 2020 @ 2PM

BIDDER/RESPONDER SHALL CONFORM TO THE FOLLOWING CHANGES AS SAME SHALL BECOME BINDING UPON THE CONTRACT TO BE ISSUED IN RESPONSE TO THIS INVITATION FOR BID.

Norse Hall Exterior Repairs

1. SEE QUESTION BELOW – ANSWER IN RED TEXT

- Should our scope include doing the cove caulking at the ground level?

Yes, include replacement of the cove sealant at ground level. No traffic membrane coating or vapor barrier are to be installed on the ground level.

Holly C. Vasquez

Procurement Services Manager
Northern Kentucky University
617 Lucas Administrative Center
Highland Heights, KY 41099
vasquezh1@nku.edu
O: (859) 572-5171
F: (859) 572-6995

**END OF
ADDENDUM**

HCV-05/08/2020