



Procurement Services  
Lucas Administrative Center, 617  
1 Nunn Drive  
Highland Heights, KY 41099  
859.572.5265  
FAX 859.572.6995

**ADDENDUM NO: 1**

**IFB/RFP No:** NKU-05-19

**Commodity:** Piner Property Restoration

**Date:** 9/10/2018

**Due Date:** 9/14/2018

***BIDDER/RESPONDER SHALL CONFORM TO THE FOLLOWING CHANGES AS SAME SHALL BECOME BINDING UPON THE CONTRACT TO BE ISSUED IN RESPONSE TO THIS INVITATION FOR BID.***

1. Please see the questions / responses below.
2. Attached is a sign-in sheet from the pre-bid meeting.

What was the assumed depth on the topsoil to come up with the approximate 3200 CY.

6"

Since there is no geotech report, is it ok to track in the fills in 18" lifts?

18" is a little thick to get any good compaction. Since the only real fill is at the driveway loop near the old house, and that will not end up with any kind of structure or road on it, that should be OK. They will need to make sure they will be benching that fill in pretty well into the existing slope to make sure it doesn't slide and get the 18" lifts compacted as best they can. I would prefer 12" lifts, but 18" would probably not be a problem.

There is a new pipe that was recently installed at the gravel driveway where the gabion basket wall is to be installed. The question came up on whether that pipe should stay.

The pipe should stay. The top left note on sheet C3.1 addresses the pipe.

One of the contractors also pointed out that there was a telephone box in this area and questioned what they were supposed to do with it.

We'll do our best to work around it if it is live.

A couple of other items to point out.

- Can have up to 12 months to complete the project.
- NKU wants the earthwork done when the soils are suitable (not too wet)
- The contractor selection will be on the base bid only.

**THE END**

By: Ryan Straus  
Bid Specialist  
Procurement Services  
617 Lucas Administrative Center  
Highland Heights, KY 41099

NKU-05-19				
Piner Property Floodplain Restoration				
Pre-Bid Meeting Sign-In Sheet				
8/30/2018 @ 9:30 AM				
PLEASE PRINT INFORMATION LEGIBLY. THANK YOU.				
	NAME	COMPANY	PHONE NUMBER	E-MAIL
1	Weston Cline	Hinkle Environmental Services	606-205-4929	weston.cline@hinkle-env.com
2	Donnie Sears	HE S	604-627-0737	donnie.sears@hinkle-env.com
	Brian Bezold	Bray Const.	859-635-5681	bbezold@brayinc.com
3	Dean Stith	Hale Contracting	859-824-6331	hok.contracting@yahoo.com
4				
5				
6				
7				
8				
9				
10				