



312 PLUM STREET, SUITE 700
CINCINNATI, OHIO 45202
(513) 381-2112

November 05, 2018
ADDENDUM NO. 2

TO THE DRAWINGS, SPECIFICATIONS AND CONTRACT DOCUMENTS FOR:

Northern Kentucky University

**Commonwealth Hall Renovations
NKU-16-19**

TO ALL BIDDERS:

This addendum supplements, amends and takes precedence over the original Drawings and Specifications, and shall be taken into account when preparing proposals, and shall become part of the Contract Documents. Bidders must indicate receipt of this addendum in the space provided in the Bid Form.

GENERAL ITEMS:

Item #1: All integration to the campus central plant should be included in the bid, but must be performed by Schneider. Any contractor can install the controls, but the integration needs to be completed by Schneider.

QUESTIONS AND RESPONSES:

Item #2:

Question: Does the fire alarm needs to be tied into the campus Fireworks system?

Response: Yes.

End of Addendum #2