



Procurement Services
Lucas Administrative Center, 617
1 Nunn Drive
Highland Heights, KY 41099
859.572.6605
FAX 859.572.6995

ADDENDUM NO: 1

IFB/RFP No: NKU-18-19

Commodity: Soccer Field Turf

Date: 11/13/2018

Due Date: 11/20/2018

BIDDER/RESPONDER SHALL CONFORM TO THE FOLLOWING CHANGES AS SAME SHALL BECOME BINDING UPON THE CONTRACT TO BE ISSUED IN RESPONSE TO THIS INVITATION FOR BID.

Please see the following questions / answers:

- 1) For Alternate 1 – ADD – 2-Lane Track Straight-Away and Concrete Curb – the drawings do not indicate what the strip is to be comprised of between the existing field curb and the first asphalt/track surfaced lane. Can you identify what is to go in this area?

Both asphalt base and the synthetic surface material shall be installed in the entire area from new curb, across to the existing east curb. The two track lanes will simply be striped within this area down the center.

- 2) For Alternate 1 – ADD – 2-Lane Track Straight-Away and Concrete Curb – can you identify the required thicknesses of the asphalt lifts?

The intermediate lift shall be 2" thick, the top lift shall be 1-1/2" thick.

- 3) For Alternate 1 – ADD – 2-Lane Track Straight-Away and Concrete Curb – can you identify the required thickness of the stone base under the asphalt? Or is this to remain compacted earth? T

The stone base shall be 8" thick.

- 4) For Alternate 1 – ADD – 2-Lane Track Straight-Away and Concrete Curb – do we need to use ODOT specifications for asphalt installation in Kentucky?

ODOT may be used as the specified standard for intent, but final installation shall meet the requirements of KY if they differ.

- 5) For Alternate 1 – ADD – 2-Lane Track Straight-Away and Concrete Curb – will schedule allowances be provided if asphalt plants are closed during the construction period?

Yes, but final installation of asphalt and track surface in the spring must then be coordinated with NKU and scheduled around their use of the facility.

- 6) Will the owner be providing the team bench sleeves that will need to be set in the concrete footings?

Yes, the ground anchors will be provided by the University, but they must be set and cast into the concrete footing by the Contractor.

- 7) The drawing does not indicate that the mid-field logo is being replaced. Are we to replace this logo in the base pricing?

No, there is no mid-field logo as part of this replacement.

- 8) Is the unit pricing for the team shelter footings to be provided per shelter or per footing?

Per shelter, so essentially it will be one unit price that is identical for both shelters.

- 9) On specification section 321813, page 2 – item 1.6, part A – do these items need to be submitted with the proposal or will they be requested once lowest , most responsible Contract bidder(s) are identified?

These items shall be provided with the proposal to assist with evaluation.

- 10) On specification section 321813, page 8 – item 2.2, part C – does this recycled rubber product need to be virgin rubber – meaning this is the first athletic field this rubber is installed in?

No, as long as the rubber product meets the following: a maximum of one (1) previous field life cycle, cleaned / separated per industry standards, the product maintains the specified performance requirements (G-Max) for the full life of the field, and the product remains under warranty per the specification requirements for the full life of the field. If non-virgin rubber is included in the proposal please make note of this on the bid form.

- 11) Please identify the shock absorbing pad underlayment performance specifications – height, thickness, etc.

The shock absorbing pad may be as recommended by the vendor per the synthetic turf systems proposed. That said, please identify within the proposal, the thickness of the pad if provided.

- 12) Confirming that the base remediation is to achieve a minimum of 10” per hour across the field?

Yes, remediation shall bring the stone base drainage system back up to a 10” per hour industry standard.

- 13) Are we allowed access to the field to evaluate existing conditions during the bidding process? What is the required process for this?

Yes, coordinate all site visits with NKU, Brad Lehman lehmanb1@nku.edu, 859-572-1989

Please contact Ryan Straus with any questions.

Ryan Straus
Bid Specialist
Procurement Services
Northern Kentucky University
617 Lucas Administrative Center
Highland Heights, KY 41099
O: (859) 572-6605
F: (859) 572-6995

THE END